



Renewables & Energy Storage

**Technical, Financial and Risk analysis of
grid connected renewable energy plant with storage**

Annual Symposium HAEE, 4th Edition 2019

Niko A. ILIADIS

company presentation - Fields of Activity

■ POWER SUPPLY

– OFF - GRID SYSTEMS

- Solar Photovoltaics Systems
- Wind Power Systems
- Energy Storage Systems
- EV charging Systems

– GRID CONNECTED SYSTEMS

- Solar Photovoltaics
- Wind Power Systems
- Small and Large hydroelectric systems
- Solid and liquid biomass energy systems
- Biogas energy systems
- Co-generation systems
- Diesel, Petrol and Gas Generators systems
- Energy Storage Systems
- EV charging System

■ LIGHTING PV SYSTEMS

■ SOLAR STRUCTURES

- CAR PORT (ENERPORT)
- WAREHOUSE AND SOLARHOUSES

■ SERVICES SUPPLIER






– SERVICES


- Engineering Services
- Financing Services
- Due Diligence Services

main components of microgrid systems

- System components

- Classification

-  Microgrid controller
-  Conventional Generation
-  Renewable Generation
-  Battery Energy Storage System
-  Demand



Source: Renemig

generation categories

- Generation: conventional vs renewables
 - **Categories of electricity generation technologies**
 - **Conventional**
 - Gas ,Diesel, HFO, Kerosene, large hydro
 - **Controllable**
 - Fuel based generator, biomass ¹, hydro dam, Rankine cycle ²
 - **Storable**
 - Hydro dam, fuel based generator ³
 - **Location dependent**
 - Hydro, solar, wind, biomass ⁴, tidal, Rankine cycle
 - **With by-product**
 - Fuel based generator, biomass, biogas, solar ⁶
 - **Renewable**
 - Solar, wind, biomass, biogas, tidal, small hydro, Rankine cycle
 - **Uncontrollable**
 - RoR hydro, solar, wind, tidal
 - **Non-storable**
 - All others
 - **Location independent**
 - Fuel based generator ⁵,
 - **Without by-product**
 - Wind, Rankine cycle, tidal,

1: depending on the technology

2: low variation

3: Natural gas requires special installation


4: if biomass can be transported (chips vs pellet, waste, etc.)

5: Gas requires storage

6: special modules are required

generation technologies sizes vs LCOE

- Generation: conventional vs renewables
 - **Generation sizes**



renewable penetration, excess energy, diesel consumption / grid power use

- Excess energy: loss and use

- **Definition of excess energy**

- The energy that cannot be used from the system in a period of specific time

- **Definition of excess power**

- The power that cannot be absorbed instantaneously from the system

A system that can absorb the excess energy does not mean that it can absorb the excess power

- **Managing excess energy**

- Additional ESS energy capacity is required
- ESS with important depth of discharge are used
- ESS with low cost of capacity

- **Managing excess power**

- Additional ESS power capacity is required
- ESS with high C rates are used
- ESS with low cost of C rates

- **Use of excess energy**

- Deferrable loads
- Battery charging






- **Use of excess power**


- Dump loads

main components of microgrid systems

- Controls

- Classification

-  Energy management system (microgrid controller)
-  Generation controls
-  Battery Management System
-  Load controls
-  External units controls



Source: Renemig

system revenues, operating costs and cashflow

- Forms of revenue
 - **FIT**
 - Fixed (uniform, reverse auction)
 - Indexed on the electricity market exchange price

 - **PPA**
 - Fixed price
 - Indexed on the electricity market
 - Indexed on a fuel price
 - Performance based (RES fraction, power quality, number of outages)


 - **Savings**
 - Grid cost savings
 - Fuel consumption savings
 - Operation savings (power quality improvement, outages elimination)
 - Maintenance savings
 - Emissions savings

diesel based industrial microgrid

- Mine
 - **Location:** East Africa
 - **Load:** 48.2 GWh/y | 5.5 MWa | 6.1 MW peak
 - **Initial configuration**
 - Generation: 10 MVA diesel generators
 - Power cost: 0.38 – 0.44 USD/kWh (1.2 USD/l) (calculated – on the field)
 - **Approach:** specific budget, redeployable
 - **PPA Duration:** 10 years

 - **Solution A**
 - 30% of PV penetration => 1.65 MWp
 - No ESS
 - CapEx: 2.6 M USD
 - Comments:
 - Pros: low cost, lower maintenance
 - Cons: irregular generator usage, lower fuel efficiency, lower power quality
 - **Solution B**
 - 110% of PV penetration => 6.1 MWp
 - ESS = 3 MWh (stability purposes mainly) Lithium
 - CapEx: 10.7 M USD
 - Comments:
 - Pros: low cost, lower maintenance, better generator usage
 - Cons: higher CapEx,

diesel based industrial microgrid



financial calculation

■ Project economics

- **CapEx:** 10.7 M USD
- **LCOE:** 0.28 USD/kWh
- **Fuel savings:** 623 k USD / year

- Sensitivity analysis of LCOE [USD/kWh]:

- lifetime [y] vs cost of capital [%]

| Levelised cost of power (USD / kWh) | | 10.0% | 12.5% | 15.0% | 17.5% | 20.0% |
|-------------------------------------|----|-------|-------|--------------|-------|-------|
| Lifetime | 6 | 0.312 | 0.333 | 0.354 | 0.376 | 0.398 |
| | 8 | 0.262 | 0.283 | 0.305 | 0.328 | 0.351 |
| | 10 | 0.233 | 0.255 | 0.278 | 0.302 | 0.326 |
| | 12 | 0.215 | 0.237 | 0.261 | 0.286 | 0.311 |


- Sensitivity analysis of fuel and O&M savings:

- Fuel cost [USD/l] vs cost of capital [%]

| Annual fuel savings + diesel maintenance savings | | Cost of capital | | | | |
|--|------|-----------------|-----------|----------------|-----------|---------|
| | | 10.0% | 12.5% | 15.0% | 17.5% | 20.0% |
| Diesel fuel cost (USD / kWh) | 0.30 | 845'021 | 648'431 | 443'551 | 231'075 | 11'685 |
| | 0.32 | 1'024'586 | 827'996 | 623'116 | 410'640 | 191'250 |
| | 0.34 | 1'204'151 | 1'007'561 | 802'681 | 590'205 | 370'815 |
| | 0.36 | 1'383'716 | 1'187'127 | 982'247 | 769'771 | 550'381 |
| | 0.38 | 1'563'281 | 1'366'692 | 1'161'812 | 949'336 | 729'946 |
| | 0.40 | 1'742'846 | 1'546'257 | 1'341'377 | 1'128'901 | 909'511 |

public microgrid with PV, RES and diesel

- Island
 - **Location:** North Aegean sea
 - **Load:** 148 GWh | 16.9 MWa | 43.6 MW peak
 - **Initial configuration**
 - Generation
 - HFO generators: 56.3 MW
 - Wind power: 8 MW
 - PV power: 4.4 MWp
 - **Approach:** RES penetration increase
 - **PPA Duration:** 25 years



Source: Renemig




wind, solar and total RES

Wind power

- **Energy:** 23.4 GWh
- **Standard Deviation:** 3'344 MW
- **Coefficient of Variation:** 1.25



PV power

- **Energy:** 7.4 GWh
- **Standard Deviation:** 1'147 MW
- **Coefficient of Variation:** 0.68



load and total RES


- Total RES without any curtailment reaches 117% penetration
- For grid stability purposes, the Max RES penetration is limited at 30% curtailing 9.6 GWh per year which represents 28% of RES energy produced



curtailed power for Max penetration 40%, 50%, 75% and unrestricted (117%)

- Penetration increase pros
 - Energy saved
 - CO2 decrease


- Penetration increase cons
 - Grid outages
 - Power quality decrease
 - Fuel increase
 - Maintenance increase



RES curtailment and BESS size

- Currently RES systems can reach penetrations over 100% using the appropriate technology (BESS, generation & load mgt.)
- The size of BESS is calculated based on the variation of power of the RES that should be absorbed to keep the penetration at 30%
- The BESS will be sized optimally because of the steep price decrease and thus will make multiple cycles per day
- The relation between the penetration increase and the curtailed energy is not linear
- The relation between penetration increase and BESS size is not linear, making the large systems more difficult to payback

| RES curtailment | | | | | | | | | | |
|-----------------|------------------|-------------------------|-------------------------|------------------------|---------------------------|---------------------------------|------|---------------------|------------|--------------|
| RES Max Pen. | Curtailed energy | Average curtailed power | Maximum curtailed power | Curtailment occurrence | Curtailed fraction of RES | Δ curtailed energy from 30% pen | | Cost of Curtailment | Saved cost | Size of BESS |
| [%] | [GWh] | [MW] | [MW] | [%] | [%] | [GWh] | [MW] | [M EUR] | [M EUR] | [MWh] |
| 30% | 9.6 | 3.3 | 8.3 | 33 | 28 | | | 1.48 | | |
| 40% | 5.7 | 2.6 | 7.3 | 25 | 21 | 3.9 | 1.4 | | 0.60 | 3.3 |
| 50% | 3.0 | 1.9 | 6.4 | 18 | 15 | 6.6 | 2.3 | | 1.02 | 6.3 |
| 60% | 1.3 | 1.4 | 5.4 | 11 | 12 | 8.3 | 2.9 | | 1.28 | 8.5 |
| 75% | 0.3 | 1.2 | 4.0 | 3 | 10 | 9.3 | 3.2 | | 1.44 | 10.2 |



financial calculation


financial model assumptions

- Targeted RES penetration: 40%
- BESS size: 3.3 MWh
- Converter size: 2.6 MW
- BESS CapEx: 1.25 M EUR
- BESS OpEx: 16.6 k EUR/year
- Total cycles before replacement: 5'000

- Cost of equity: 8%


- PPA duration: 25 years
- PPA storage use price: 0.105 EUR/kWh

- Project IRR: 9.5%
- LCOES: 0.09 EUR/kWh



project risk analysis


- Country risk
 - Credit rating
 - Debt provision
 - Strategic stability
- Regulatory risk
 - PPA price change
 - PPA duration change
 - Dispatching curve
- Counterparty risk
 - Shareholders
 - Insurance capability
- Technology risk
 - Technology maturity



the next step


- Introduction of storage systems
- Structural change of the PPA to include:
 - emissions remuneration
 - improvement of power quality
 - ancillary services provision
 - impact on O&M of the system
- Creation of the appropriate markets
 - frequency regulation
 - voltage support
 - primary reserve
 - black start

EU Emission Allowances | Secondary Market



Trend Data for Battery Pack \$/kWh - Tesla vs. Market Average (BNEF research)

{Cost Axis is Log Scale, dashed lines are estimated data}





contact

EST RES Ltd.

Switzerland

Address: Rue de Lausanne 85, Geneva, GE, Switzerland

Greece

Address: N. Plastira Street 4, 171 21 Nea Smyrni, Greece

Email: office@est-res.com

URL: www.est-res.com

Local Partners

Australia

Benin

D.R. of Congo

France

Ghana

India

Indonesia

Israel

Kenya

Malaysia

Turkey